

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
Target Air Quality Levels										NA	Air Quality Levels	Site Specific Trigger Levels	
EPA Site Specific Trigger Levels										70			
ASBESTOS-ST1-12/5/08	030842904-0001	Southwest Area (sidewalk bridge level)	12/5/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST2-12/5/08	030842904-0002	Southeast Area (sidewalk bridge level)	12/5/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST4-12/5/08	030842904-0003	Northwest Area (street-level)	12/5/08	1	3.120	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST5-12/5/08	030842904-0004	Firehouse #10 (roof level)	12/5/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST10-12/5/08	030842904-0005	North Side Sidewalk Bridge	12/5/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST11-12/5/08	030842904-0006	90 Trinity Place (roof level)	12/5/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST12-12/5/08	030842904-0007	110 Greenwich Street (roof level)	12/5/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST13-12/5/08	030842904-0008	Marriott Hotel, 38th Floor (roof level)	12/5/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST14-12/5/08	030842904-0009	West Face - South end at corner (scaffolding level)	12/5/08	1	2.860	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST15-12/5/08	030842904-0010	South Face - East end at corner (scaffolding level)	12/5/08	1	2.890	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST16-12/5/08	030842904-0011	East Face - North end at corner (scaffolding level)	12/5/08	1	2.850	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST17-12/5/08	030842904-0012	North Face - West end at corner (scaffolding level)	12/5/08	1	2.840	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST1-12/6/08	030842972-0001	Southwest Area (sidewalk bridge level)	12/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST2-12/6/08	030842972-0002	Southeast Area (sidewalk bridge level)	12/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST4-12/6/08	030842972-0003	Northwest Area (street-level)	12/6/08	1	2.510	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 11.00	No	No	Note 1
ASBESTOS-ST5-12/6/08	030842972-0004	Firehouse #10 (roof level)	12/6/08	1	2.900	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST10-12/6/08	030842972-0005	North Side Sidewalk Bridge	12/6/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST11-12/6/08	030842972-0006	90 Trinity Place (roof level)	12/6/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST12-12/6/08	030842972-0007	110 Greenwich Street (roof level)	12/6/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST13-12/6/08	030842972-0008	Marriott Hotel, 38th Floor (roof level)	12/6/08	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST14-12/6/08	030842972-0009	West Face - South end at corner (scaffolding level)	12/6/08	1	2.920	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST15-12/6/08	030842972-0010	South Face - East end at corner (scaffolding level)	12/6/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST16-12/6/08	030842972-0011	East Face - North end at corner (scaffolding level)	12/6/08	1	2.930	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST17-12/6/08	030842972-0012	North Face - West end at corner (scaffolding level)	12/6/08	1	2.990	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST1-12/7/08	030842973-0001	Southwest Area (sidewalk bridge level)	12/7/08	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST2-12/7/08	030842973-0002	Southeast Area (sidewalk bridge level)	12/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST4-12/7/08	030842973-0003	Northwest Area (street-level)	12/7/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST5-12/7/08	030842973-0004	Firehouse #10 (roof level)	12/7/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST10-12/7/08	030842973-0005	North Side Sidewalk Bridge	12/7/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST11-12/7/08	030842973-0006	90 Trinity Place (roof level)	12/7/08	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST12-12/7/08	030842973-0007	110 Greenwich Street (roof level)	12/7/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 13.00	No	No	
ASBESTOS-ST13-12/7/08	030842973-0008	Marriott Hotel, 38th Floor (roof level)	12/7/08	1	3.100	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST14-12/7/08	030842973-0009	West Face - South end at corner (scaffolding level)	12/7/08	1	3.200	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST15-12/7/08	030842973-0010	South Face - East end at corner (scaffolding level)	12/7/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST16-12/7/08	030842973-0011	East Face - North end at corner (scaffolding level)	12/7/08	1	3.250	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	
ASBESTOS-ST17-12/7/08	030842973-0012	North Face - West end at corner (scaffolding level)	12/7/08	1	3.280	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/8/08	< 15.00	No	No	

Note:

1. The asbestos sample from Station 4 (Northwest Area [street-level]) on December 6, 2008 is of a reduced volume on account of a power outage.