

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments
										NA	Air Quality Levels	Site Specific Trigger Levels	
										70			
ASBESTOS-ST1-12/8/08	030843127-0001	Southwest Area (sidewalk bridge level)	12/8/08	1	2.690	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST2-12/8/08	030843127-0002	Southeast Area (sidewalk bridge level)	12/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST4-12/8/08	030843127-0003	Northwest Area (street-level)	12/8/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST5-12/8/08	030843127-0004	Firehouse #10 (roof level)	12/8/08	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST10-12/8/08	030843127-0005	North Side Sidewalk Bridge	12/8/08	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST11-12/8/08	030843127-0006	90 Trinity Place (roof level)	12/8/08	1	3.110	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST12-12/8/08	030843127-0007	110 Greenwich Street (roof level)	12/8/08	1	3.160	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST13-12/8/08	030843127-0008	Marriott Hotel, 38th Floor (roof level)	12/8/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST14-12/8/08	030843127-0009	West Face - South end at corner (scaffolding level)	12/8/08	1	3.210	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST15-12/8/08	030843127-0010	South Face - East end at corner (scaffolding level)	12/8/08	1	3.170	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST16-12/8/08	030843127-0011	East Face - North end at corner (scaffolding level)	12/8/08	1	3.080	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	
ASBESTOS-ST17-12/8/08	030843127-0012	North Face - West end at corner (scaffolding level)	12/8/08	1	3.240	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/9/08	< 13.00	No	No	