

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
										NA	Air Quality Levels	Site Specific Trigger Levels		
										70				
Target Air Quality Levels														
EPA Site Specific Trigger Levels														
ASBESTOS-ST1-12/14/05	030537438-0001	Southwest Area (sidewalk bridge level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST2-12/14/05	030537438-0002	Southeast Area (sidewalk bridge level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST4-12/14/05	030537438-0003	Northwest Area (street-level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST5-12/14/05	030537438-0004	Firehouse #10 (roof level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST10-12/14/05	030537438-0005	North Side Sidewalk Bridge	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST11-12/14/05	030537438-0006	90 Trinity Place (roof level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST12-12/14/05	030537438-0007	110 Greenwich Street (roof level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST13-12/14/05	030537438-0008	Marriott Hotel, 38th Floor (roof level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST14-12/14/05	030537438-0009	West Face - South end at corner (scaffolding level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST15-12/14/05	030537438-0010	South Face - East end at corner (scaffolding level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST16-12/14/05	030537438-0011	East Face - North end at corner (scaffolding level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST17-12/14/05	030537438-0012	North Face - West end at corner (scaffolding level)	12/14/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/15/05	< 13.00	No	No		
ASBESTOS-ST1-12/15/05	030537626-0001	Southwest Area (sidewalk bridge level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST2-12/15/05	030537626-0002	Southeast Area (sidewalk bridge level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST4-12/15/05	030537626-0003	Northwest Area (street-level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST5-12/15/05	030537626-0004	Firehouse #10 (roof level)	12/15/05	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST10-12/15/05	030537626-0005	North Side Sidewalk Bridge	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST11-12/15/05	030537626-0006	90 Trinity Place (roof level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST12-12/15/05	030537626-0007	110 Greenwich Street (roof level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST13-12/15/05	030537626-0008	Marriott Hotel, 38th Floor (roof level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST14-12/15/05	030537626-0009	West Face - South end at corner (scaffolding level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST15-12/15/05	030537626-0010	South Face - East end at corner (scaffolding level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST16-12/15/05	030537626-0011	East Face - North end at corner (scaffolding level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		
ASBESTOS-ST17-12/15/05	030537626-0012	North Face - West end at corner (scaffolding level)	12/15/05	1	2.970	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/16/05	< 13.00	No	No		