

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										NA			
										70			
ASBESTOS-ST1-12/23/08	030844669-0001	Southwest Area (sidewalk bridge level)	12/23/08	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST2-12/23/08	030844669-0002	Southeast Area (sidewalk bridge level)	12/23/08	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST4-12/23/08	030844669-0003	Northwest Area (street-level)	12/23/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST5-12/23/08	030844669-0004	Firehouse #10 (roof level)	12/23/08	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST10-12/23/08	030844669-0005	North Side Sidewalk Bridge	12/23/08	1	2.910	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST11-12/23/08	030844669-0006	90 Trinity Place (roof level)	12/23/08	1	3.000	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST12-12/23/08	030844669-0007	110 Greenwich Street (roof level)	12/23/08	1	2.980	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 13.00	No	No	
ASBESTOS-ST13-12/23/08	030844669-0008	Marriott Hotel, 38th Floor (roof level)	12/23/08	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 15.00	No	No	
ASBESTOS-ST14-12/23/08	030844669-0009	West Face - South end at corner (scaffolding level)	12/23/08	1	2.360	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 11.00	No	No	
ASBESTOS-ST15-12/23/08	030844669-0010	South Face - East end at corner (scaffolding level)	12/23/08	1	2.370	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 11.00	No	No	
ASBESTOS-ST16-12/23/08	030844669-0011	East Face - North end at corner (scaffolding level)	12/23/08	1	2.660	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 11.00	No	No	
ASBESTOS-ST17-12/23/08	030844669-0012	North Face - West end at corner (scaffolding level)	12/23/08	1	2.450	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/24/08	< 11.00	No	No	