

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos AHERA Concentration (S/mm2)	Exceeds Target	Exceeds EPA	Comments	
Target Air Quality Levels											NA	Air Quality	Site Specific	Comments
EPA Site Specific Trigger Levels											70	Levels	Trigger Levels	
ASBESTOS-ST1-12/27/06	030641696-0001	Southwest Area (sidewalk bridge level)	12/27/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 13.00	No	No		
ASBESTOS-ST2-12/27/06	030641696-0002	Southeast Area (sidewalk bridge level)	12/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST4-12/27/06	030641696-0003	Northwest Area (street-level)	12/27/06	1	2.680	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 13.00	No	No	Note 1	
ASBESTOS-ST5-12/27/06	030641696-0004	Firehouse #10 (roof level)	12/27/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST10-12/27/06	030641696-0005	North Side Sidewalk Bridge	12/27/06	1	2.960	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 13.00	No	No		
ASBESTOS-ST11-12/27/06	030641696-0006	90 Trinity Place (roof level)	12/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST12-12/27/06	030641696-0007	110 Greenwich Street (roof level)	12/27/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 13.00	No	No		
ASBESTOS-ST13-12/27/06	030641696-0008	Marriott Hotel, 38th Floor (roof level)	12/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST14-12/27/06	030641696-0009	West Face - South end at corner (scaffolding level)	12/27/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST15-12/27/06	030641696-0010	South Face - East end at corner (scaffolding level)	12/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST16-12/27/06	030641696-0011	East Face - North end at corner (scaffolding level)	12/27/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST17-12/27/06	030641696-0012	North Face - West end at corner (scaffolding level)	12/27/06	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/28/06	< 15.00	No	No		
ASBESTOS-ST1-12/28/06	030641808-0001	Southwest Area (sidewalk bridge level)	12/28/06	1	3.010	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST2-12/28/06	030641808-0002	Southeast Area (sidewalk bridge level)	12/28/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST4-12/28/06	030641808-0003	Northwest Area (street-level)	12/28/06	1	3.060	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST5-12/28/06	030641808-0004	Firehouse #10 (roof level)	12/28/06	1	2.940	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST10-12/28/06	030641808-0005	North Side Sidewalk Bridge	12/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST100-12/28/06	030641808-0013	Station 10 Field Duplicate	12/28/06	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST11-12/28/06	030641808-0006	90 Trinity Place (roof level)	12/28/06	1	3.050	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST12-12/28/06	030641808-0007	110 Greenwich Street (roof level)	12/28/06	1	3.040	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST13-12/28/06	030641808-0008	Marriott Hotel, 38th Floor (roof level)	12/28/06	1	3.030	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST14-12/28/06	030641808-0009	West Face - South end at corner (scaffolding level)	12/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST15-12/28/06	030641808-0010	South Face - East end at corner (scaffolding level)	12/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST16-12/28/06	030641808-0011	East Face - North end at corner (scaffolding level)	12/28/06	1	3.070	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		
ASBESTOS-ST17-12/28/06	030641808-0012	North Face - West end at corner (scaffolding level)	12/28/06	1	3.020	Asbestos	TEM EPA 40 CFR PART 763 (AHERA)	EMSL	12/29/06	< 13.00	No	No		

Note:

1. Due to flow rate RPD exceedance (25.9%) for asbestos at Station 4 (Northwest Area [street-level]) on December 27, 2006, the sample volume and subsequent sample result are estimated.