

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Antimony Concentration (ng/m ³)	Barium Concentration (ng/m ³)	Beryllium Concentration (ng/m ³)	Cadmium Concentration (ng/m ³)	Chromium (Total) Concentration (ng/m ³)	Copper Concentration (ng/m ³)	Lead Concentration (ng/m ³)	Manganese Concentration (ng/m ³)	Nickel Concentration (ng/m ³)	Zinc Concentration (ng/m ³)	Exceeds Target	Exceeds EPA	Comments		
									5,000	5,000	20	40	600	10,000	1,500	500	200	16,000					
									14,000	5,000	200	400	600	100,000	5,000	500	28,000	160,000					
									Air Quality Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels	Site Specific Trigger Levels			
METALS-ST11-1/4/06	G6A060292001	Southwest Area (sidewalk bridge level)	1/4/06	1756.2	Metals	6020	STL-SAC	1/6/06	3.7	< 68.3	< 0.68	< 0.68	< 6.8	36.3	188	17.7	44.2	86.4	No	No			
METALS-ST2-1/4/06	G6A060292002	Southeast Area (sidewalk bridge level)	1/4/06	1696.7	Metals	6020	STL-SAC	1/6/06	4.5	< 74.7	< 0.75	< 0.75	7.8	121	215	43.8	50.8	124	No	No			
METALS-ST4-1/4/06	G6A060292003	Northwest Area (street-level)	1/4/06	1646.6	Metals	6020	STL-SAC	1/6/06	4.2	< 72.9	< 0.73	< 0.73	< 7.3	212	166	20.3	52.7	86.6	No	No			
METALS-ST5-1/4/06	G6A060292004	Firehouse #10 (roof level)	1/4/06	1680.9	Metals	6020	STL-SAC	1/6/06	3.7	< 71.4	< 0.71	< 0.71	< 7.1	86.2	103	26.7	44.7	76.2	No	No			
METALS-ST10-1/4/06	G6A060292005	North Side Sidewalk Bridge	1/4/06	1791.5	Metals	6020	STL-SAC	1/6/06	3.7	< 67.0	< 0.67	< 0.67	< 6.7	41.9	73.8	21.1	49.2	70.2	No	No			
METALS-ST11-1/4/06	G6A060292006	90 Trinity Place (roof level)	1/4/06	1634.8	Metals	6020	STL-SAC	1/6/06	4.0	< 73.4	< 0.73	< 0.73	< 7.3	200	435	21.7	54.8	132	No	No			
METALS-ST12-1/4/06	G6A060292007	110 Greenwich Street (roof level)	1/4/06	1593.9	Metals	6020	STL-SAC	1/6/06	3.6	< 75.3	< 0.75	< 0.75	< 7.5	118	282	19.0	45.5	111	No	No			
METALS-ST13-1/4/06	G6A060292008	Mariotti Hotel, 38th Floor (roof level)	1/4/06	1705.7	Metals	6020	STL-SAC	1/6/06	3.4	< 70.4	< 0.70	< 0.70	< 7.0	221	217	16.3	46.8	86.7	No	No			
METALS-ST14-1/4/06	G6A060292009	West Face - South end at corner (scaffolding level)	1/4/06	1753	Metals	6020	STL-SAC	1/6/06	2.4	< 68.4	< 0.68	< 0.68	< 6.8	157	157	12.4	31.3	64.3	No	No			
METALS-ST15-1/4/06	G6A060292010	South Face - East end at corner (scaffolding level)	1/4/06	1734.6	Metals	6020	STL-SAC	1/6/06	2.3	< 66.9	< 0.67	< 0.67	< 6.7	125	261	13.0	29.2	90.4	No	No			
METALS-ST16-1/4/06	G6A060292011	East Face - North end at corner (scaffolding level)	1/4/06	1698.5	Metals	6020	STL-SAC	1/6/06	2.6	< 70.6	< 0.71	< 0.71	< 7.1	115	234	15.5	31.1	90.1	No	No			
METALS-ST17-1/4/06	G6A060292012	North Face - West end at corner (scaffolding level)	1/4/06	1523.5	Metals	6020	STL-SAC	1/6/06	3.0	< 78.8	< 0.79	< 0.79	< 7.9	131	127	17.3	36.8	70.6	No	No			
METALS-ST1-1/5/06	G6A090122001	Southwest Area (sidewalk bridge level)	1/5/06	1785	Metals	6020	STL-SAC	1/9/06	2.8	< 67.2	< 0.67	< 0.67	< 6.7	305	16.9	12.4	9.5	53.5	No	No			
METALS-ST2-1/5/06	G6A090122002	Southeast Area (sidewalk bridge level)	1/5/06	1643.9	Metals	6020	STL-SAC	1/9/06	3.4	< 73.0	< 0.73	< 0.73	< 7.3	54.4	23.4	12.1	17.3	78.0	No	No			
METALS-ST4-1/5/06	G6A090122003	Northwest Area (street-level)	1/5/06	1618	Metals	6020	STL-SAC	1/9/06	2.2	< 74.2	< 0.74	< 0.74	< 7.4	317	16.0	9.1	9.0	49.8	No	No			
METALS-ST5-1/5/06	G6A090122004	Firehouse #10 (roof level)	1/5/06	1761.5	Metals	6020	STL-SAC	1/9/06	2.2	< 68.1	< 0.68	< 0.68	< 6.8	64.9	13.3	20.9	9.6	50.7	No	No			
METALS-ST10-1/5/06	G6A090122005	North Side Sidewalk Bridge	1/5/06	1676.9	Metals	6020	STL-SAC	1/9/06	2.0	< 71.6	< 0.72	< 0.72	< 7.2	25.1	8.0	11.1	9.6	37.9	No	No			
METALS-ST11-1/5/06	G6A090122006	90 Trinity Place (roof level)	1/5/06	1627.3	Metals	6020	STL-SAC	1/9/06	2.3	< 73.7	< 0.74	< 0.74	< 7.4	59.4	9.1	12.5	10.8	45.5	No	No			
METALS-ST12-1/5/06	G6A090122007	110 Greenwich Street (roof level)	1/5/06	1617.5	Metals	6020	STL-SAC	1/9/06	2.4	< 74.2	< 0.74	< 0.74	< 7.4	51.6	10.7	12.0	11.3	49.4	No	No			
METALS-ST13-1/5/06	G6A090122008	Mariotti Hotel, 38th Floor (roof level)	1/5/06	1682.9	Metals	6020	STL-SAC	1/9/06	1.7	< 71.3	< 0.71	< 0.71	< 7.1	54.0	5.9	7.1	10	30.0	No	No			
METALS-ST14-1/5/06	G6A090122009	West Face - South end at corner (scaffolding level)	1/5/06	1683.6	Metals	6020	STL-SAC	1/9/06	1.7	< 71.3	< 0.71	< 0.71	< 7.1	63.4	6.5	6.8	8.0	40.8	No	No			
METALS-ST15-1/5/06	G6A090122010	South Face - East end at corner (scaffolding level)	1/5/06	1749.7	Metals	6020	STL-SAC	1/9/06	1.7	< 68.6	< 0.69	< 0.69	< 6.9	50.7	7.9	8.7	9.6	35.0	No	No			
METALS-ST16-1/5/06	G6A090122011	East Face - North end at corner (scaffolding level)	1/5/06	1692.1	Metals	6020	STL-SAC	1/9/06	1.9	< 70.9	< 0.71	< 0.71	< 7.1	71.6	8.3	11.2	9.0	57.3	No	No			
METALS-ST17-1/5/06	G6A090122012	North Face - West end at corner (scaffolding level)	1/5/06	1492.2	Metals	6020	STL-SAC	1/9/06	1.8	< 80.4	< 0.80	< 0.80	< 8.0	67.7	6.9	8.9	8.3	35.2	No	No			