

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-1/12/06	030601211-0001	Southwest Area (sidewalk bridge level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST2-1/12/06	030601211-0002	Southeast Area (sidewalk bridge level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST4-1/12/06	030601211-0003	Northwest Area (street-level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST5-1/12/06	030601211-0004	Firehouse #10 (roof level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST10-1/12/06	030601211-0005	North Side Sidewalk Bridge	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST11-1/12/06	030601211-0006	90 Trinity Place (roof level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST12-1/12/06	030601211-0007	110 Greenwich Street (roof level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST13-1/12/06	030601211-0008	Marriott Hotel, 38th Floor (roof level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST14-1/12/06	030601211-0009	West Face - South end at corner (scaffolding level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST15-1/12/06	030601211-0010	South Face - East end at corner (scaffolding level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST16-1/12/06	030601211-0011	East Face - North end at corner (scaffolding level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	
ASBESTOS-ST17-1/12/06	030601211-0012	North Face - West end at corner (scaffolding level)	1/12/06	1	2.970	Asbestos	PCME	EMSL	1/13/06	< 0.00083	No	No	