

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
										0.0009			
										NA			
ASBESTOS-ST1-2/6/07	030703865-0001	Southwest Area (sidewalk bridge level)	2/6/07	1	3.020	Asbestos	PCME	EMSL	2/7/07	< 0.00082	No	No	
ASBESTOS-ST2-2/6/07	030703865-0002	Southeast Area (sidewalk bridge level)	2/6/07	1	3.040	Asbestos	PCME	EMSL	2/7/07	< 0.00081	No	No	
ASBESTOS-ST4-2/6/07	030703865-0003	Northwest Area (street-level)	2/6/07	1	3.080	Asbestos	PCME	EMSL	2/7/07	< 0.00080	No	No	
ASBESTOS-ST5-2/6/07	030703865-0004	Firehouse #10 (roof level)	2/6/07	1	3.020	Asbestos	PCME	EMSL	2/7/07	< 0.00082	No	No	
ASBESTOS-ST10-2/6/07	030703865-0005	North Side Sidewalk Bridge	2/6/07	1	3.120	Asbestos	PCME	EMSL	2/7/07	< 0.00079	No	No	
ASBESTOS-ST11-2/6/07	030703865-0006	90 Trinity Place (roof level)	2/6/07	1	3.040	Asbestos	PCME	EMSL	2/7/07	< 0.00081	No	No	
ASBESTOS-ST12-2/6/07	030703865-0007	110 Greenwich Street (roof level)	2/6/07	1	3.040	Asbestos	PCME	EMSL	2/7/07	< 0.00081	No	No	
ASBESTOS-ST13-2/6/07	030703865-0008	Marriott Hotel, 38th Floor (roof level)	2/6/07	1	3.020	Asbestos	PCME	EMSL	2/7/07	< 0.00082	No	No	
ASBESTOS-ST14-2/6/07	030703865-0009	West Face - South end at corner (scaffolding level)	2/6/07	1	3.030	Asbestos	PCME	EMSL	2/7/07	< 0.00081	No	No	
ASBESTOS-ST15-2/6/07	030703865-0010	South Face - East end at corner (scaffolding level)	2/6/07	1	3.010	Asbestos	PCME	EMSL	2/7/07	< 0.00082	No	No	
ASBESTOS-ST16-2/6/07	030703865-0011	East Face - North end at corner (scaffolding level)	2/6/07	1	3.050	Asbestos	PCME	EMSL	2/7/07	< 0.00081	No	No	
ASBESTOS-ST17-2/6/07	030703865-0012	North Face - West end at corner (scaffolding level)	2/6/07	1	3.010	Asbestos	PCME	EMSL	2/7/07	< 0.00082	No	No	