

| TRC Field Sample No.                    | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target     | Exceeds EPA                              | Comments |
|---|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|--------------------|--|----------|
|   |                |   |                       |            |                                 |          |                   |      |                         | 0.0009                              | Air Quality Levels | Exceeds EPA Site Specific Trigger Levels |          |
|   |                |   |                       |            |                                 |          |                   |      |                         | NA                                  |                    |  |          |
| <b>Target Air Quality Levels</b>        |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |  |          |
| <b>EPA Site Specific Trigger Levels</b> |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |  |          |
| ASBESTOS-ST1-4/25/07                    | 030712901-0001 | Southwest Area (sidewalk bridge level)              | 4/25/07               | 1          | 2.890                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00085                           | No                 | No                                       |          |
| ASBESTOS-ST2-4/25/07                    | 030712901-0002 | Southeast Area (sidewalk bridge level)              | 4/25/07               | 1          | 2.770                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00089                           | No                 | No                                       |          |
| ASBESTOS-ST4-4/25/07                    | 030712901-0003 | Northwest Area (street-level)                       | 4/25/07               | 1          | 3.100                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00080                           | No                 | No                                       |          |
| ASBESTOS-ST5-4/25/07                    | 030712901-0004 | Firehouse #10 (roof level)                          | 4/25/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST10-4/25/07                   | 030712901-0005 | North Side Sidewalk Bridge                          | 4/25/07               | 1          | 2.800                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00088                           | No                 | No                                       |          |
| ASBESTOS-ST11-4/25/07                   | 030712901-0006 | 90 Trinity Place (roof level)                       | 4/25/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST12-4/25/07                   | 030712901-0007 | 110 Greenwich Street (roof level)                   | 4/25/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST13-4/25/07                   | 030712901-0008 | Marriott Hotel, 38th Floor (roof level)             | 4/25/07               | 1          | 3.020                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST14-4/25/07                   | 030712901-0009 | West Face - South end at corner (scaffolding level) | 4/25/07               | 1          | 3.020                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST15-4/25/07                   | 030712901-0010 | South Face - East end at corner (scaffolding level) | 4/25/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST16-4/25/07                   | 030712901-0011 | East Face - North end at corner (scaffolding level) | 4/25/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST17-4/25/07                   | 030712901-0012 | North Face - West end at corner (scaffolding level) | 4/25/07               | 1          | 3.020                           | Asbestos | PCME              | EMSL | 4/26/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST1-4/26/07                    | 030713035-0001 | Southwest Area (sidewalk bridge level)              | 4/26/07               | 1          | 3.010                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST2-4/26/07                    | 030713035-0002 | Southeast Area (sidewalk bridge level)              | 4/26/07               | 1          | 2.990                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00083                           | No                 | No                                       |          |
| ASBESTOS-ST4-4/26/07                    | 030713035-0003 | Northwest Area (street-level)                       | 4/26/07               | 1          | 3.060                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST5-4/26/07                    | 030713035-0004 | Firehouse #10 (roof level)                          | 4/26/07               | 1          | 3.010                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST10-4/26/07                   | 030713035-0005 | North Side Sidewalk Bridge                          | 4/26/07               | 1          | 2.930                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00084                           | No                 | No                                       |          |
| ASBESTOS-ST11-4/26/07                   | 030713035-0006 | 90 Trinity Place (roof level)                       | 4/26/07               | 1          | 3.030                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST12-4/26/07                   | 030713035-0007 | 110 Greenwich Street (roof level)                   | 4/26/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST13-4/26/07                   | 030713035-0008 | Marriott Hotel, 38th Floor (roof level)             | 4/26/07               | 1          | 3.020                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST14-4/26/07                   | 030713035-0009 | West Face - South end at corner (scaffolding level) | 4/26/07               | 1          | 3.000                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST15-4/26/07                   | 030713035-0010 | South Face - East end at corner (scaffolding level) | 4/26/07               | 1          | 3.020                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |
| ASBESTOS-ST16-4/26/07                   | 030713035-0011 | East Face - North end at corner (scaffolding level) | 4/26/07               | 1          | 3.040                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00081                           | No                 | No                                       |          |
| ASBESTOS-ST17-4/26/07                   | 030713035-0012 | North Face - West end at corner (scaffolding level) | 4/26/07               | 1          | 3.100                           | Asbestos | PCME              | EMSL | 4/27/07                 | < 0.00082                           | No                 | No                                       |          |