

| TRC Field Sample No.                    | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target Air Quality Levels | Exceeds EPA Site Specific Trigger Levels | Comments |
|---|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|-----------------------------------|--|----------|
| <b>Target Air Quality Levels</b>        |                |   |                       |            |                                 |          |                   |      |                         | <b>0.0009</b>                       |                                   |  |          |
| <b>EPA Site Specific Trigger Levels</b> |                |   |                       |            |                                 |          |                   |      |                         | <b>NA</b>                           |                                   |  |          |
| ASBESTOS-ST1-5/9/06                     | 030614192-0001 | Southwest Area (sidewalk bridge level)              | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST2-5/9/06                     | 030614192-0002 | Southeast Area (sidewalk bridge level)              | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST4-5/9/06                     | 030614192-0003 | Northwest Area (street-level)                       | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST5-5/9/06                     | 030614192-0004 | Firehouse #10 (roof level)                          | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST10-5/9/06                    | 030614192-0005 | North Side Sidewalk Bridge                          | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST11-5/9/06                    | 030614192-0006 | 90 Trinity Place (roof level)                       | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST12-5/9/06                    | 030614192-0007 | 110 Greenwich Street (roof level)                   | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-5/9/06                    | 030614192-0008 | Marriott Hotel, 38th Floor (roof level)             | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST14-5/9/06                    | 030614192-0009 | West Face - South end at corner (scaffolding level) | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST15-5/9/06                    | 030614192-0010 | South Face - East end at corner (scaffolding level) | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST16-5/9/06                    | 030614192-0011 | East Face - North end at corner (scaffolding level) | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST17-5/9/06                    | 030614192-0012 | North Face - West end at corner (scaffolding level) | 5/9/06                | 1          | 3.000                           | Asbestos | PCME              | EMSL | 5/10/06                 | < 0.00082                           | No                                | No                                       |          |