

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-5/18/09	030912568-0001	Southwest Area (sidewalk bridge level)	5/18/09	1	3.060	Asbestos	PCME	EMSL	5/19/09	< 0.00081	No	No	
ASBESTOS-ST2-5/18/09	030912568-0002	Southeast Area (sidewalk bridge level)	5/18/09	1	3.150	Asbestos	PCME	EMSL	5/19/09	< 0.00078	No	No	
ASBESTOS-ST4-5/18/09	030912568-0003	Northwest Area (street-level)	5/18/09	1	3.020	Asbestos	PCME	EMSL	5/19/09	< 0.00082	No	No	
ASBESTOS-ST5-5/18/09	030912568-0004	Firehouse #10 (roof level)	5/18/09	1	3.060	Asbestos	PCME	EMSL	5/19/09	< 0.00081	No	No	
ASBESTOS-ST10-5/18/09	030912568-0005	North Side Sidewalk Bridge	5/18/09	1	3.000	Asbestos	PCME	EMSL	5/19/09	< 0.00082	No	No	
ASBESTOS-ST11-5/18/09	030912568-0006	90 Trinity Place (roof level)	5/18/09	1	3.120	Asbestos	PCME	EMSL	5/19/09	< 0.00079	No	No	
ASBESTOS-ST12-5/18/09	030912568-0007	110 Greenwich Street (roof level)	5/18/09	1	3.090	Asbestos	PCME	EMSL	5/19/09	< 0.00080	No	No	
ASBESTOS-ST13-5/18/09	030912568-0008	Marriott Hotel, 38th Floor (roof level)	5/18/09	1	2.980	Asbestos	PCME	EMSL	5/19/09	< 0.00076	No	No	
ASBESTOS-ST14-5/18/09	030912568-0009	West Face - South end at corner (scaffolding level)	5/18/09	1	3.150	Asbestos	PCME	EMSL	5/19/09	< 0.00072	No	No	
ASBESTOS-ST15-5/18/09	030912568-0010	South Face - East end at corner (scaffolding level)	5/18/09	1	3.030	Asbestos	PCME	EMSL	5/19/09	< 0.00081	No	No	
ASBESTOS-ST16-5/18/09	030912568-0011	East Face - North end at corner (scaffolding level)	5/18/09	1	3.000	Asbestos	PCME	EMSL	5/19/09	< 0.00082	No	No	
ASBESTOS-ST17-5/18/09	030912568-0012	North Face - West end at corner (scaffolding level)	5/18/09	1	3.090	Asbestos	PCME	EMSL	5/19/09	< 0.00080	No	No	