

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
Target Air Quality Levels													
EPA Site Specific Trigger Levels													
ASBESTOS-ST1-6/1/06	030616817-0001	Southwest Area (sidewalk bridge level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST2-6/1/06	030616817-0002	Southeast Area (sidewalk bridge level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST4-6/1/06	030616817-0003	Northwest Area (street-level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST5-6/1/06	030616817-0004	Firehouse #10 (roof level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST10-6/1/06	030616817-0005	North Side Sidewalk Bridge	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST100-6/1/06	030616817-0013	Station 10 Field Duplicate	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST11-6/1/06	030616817-0006	90 Trinity Place (roof level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST12-6/1/06	030616817-0007	110 Greenwich Street (roof level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST13-6/1/06	030616817-0008	Marriott Hotel, 38th Floor (roof level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST14-6/1/06	030616817-0009	West Face - South end at corner (scaffolding level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST15-6/1/06	030616817-0010	South Face - East end at corner (scaffolding level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST16-6/1/06	030616817-0011	East Face - North end at corner (scaffolding level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	
ASBESTOS-ST17-6/1/06	030616817-0012	North Face - West end at corner (scaffolding level)	6/1/06	1	2.970	Asbestos	PCME	EMSL	6/2/06	< 0.00083	No	No	