

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m <sup>3</sup> )	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>										<b>0.0009</b>			
<b>EPA Site Specific Trigger Levels</b>										<b>NA</b>			
ASBESTOS-ST1-8/3/09	030920043-0001	Southwest Area (sidewalk bridge level)	8/3/09	1	2.910	Asbestos	PCME	EMSL	8/4/09	< 0.00085	No	No	
ASBESTOS-ST2-8/3/09	030920043-0002	Southeast Area (sidewalk bridge level)	8/3/09	1	2.900	Asbestos	PCME	EMSL	8/4/09	< 0.00085	No	No	
ASBESTOS-ST4-8/3/09	030920043-0003	Northwest Area (street-level)	8/3/09	1	3.010	Asbestos	PCME	EMSL	8/4/09	< 0.00082	No	No	
ASBESTOS-ST5-8/3/09	030920043-0004	Firehouse #10 (roof level)	8/3/09	1	3.060	Asbestos	PCME	EMSL	8/4/09	< 0.00081	No	No	
ASBESTOS-ST10-8/3/09	030920043-0005	North Side Sidewalk Bridge	8/3/09	1	3.050	Asbestos	PCME	EMSL	8/4/09	< 0.00081	No	No	
ASBESTOS-ST11-8/3/09	030920043-0006	90 Trinity Place (roof level)	8/3/09	1	3.150	Asbestos	PCME	EMSL	8/4/09	< 0.00078	No	No	
ASBESTOS-ST12-8/3/09	030920043-0007	110 Greenwich Street (roof level)	8/3/09	1	3.130	Asbestos	PCME	EMSL	8/4/09	< 0.00079	No	No	
ASBESTOS-ST13-8/3/09	030920043-0008	Marriott Hotel, 38th Floor (roof level)	8/3/09	1	3.030	Asbestos	PCME	EMSL	8/4/09	< 0.00081	No	No	
ASBESTOS-ST1-8/4/09	030920169-0001	Southwest Area (sidewalk bridge level)	8/4/09	1	3.040	Asbestos	PCME	EMSL	8/5/09	< 0.00081	No	No	
ASBESTOS-ST2-8/4/09	030920169-0002	Southeast Area (sidewalk bridge level)	8/4/09	1	3.120	Asbestos	PCME	EMSL	8/5/09	< 0.00079	No	No	
ASBESTOS-ST4-8/4/09	030920169-0003	Northwest Area (street-level)	8/4/09	1	2.970	Asbestos	PCME	EMSL	8/5/09	< 0.00083	No	No	
ASBESTOS-ST5-8/4/09	030920169-0004	Firehouse #10 (roof level)	8/4/09	1	3.010	Asbestos	PCME	EMSL	8/5/09	< 0.00082	No	No	
ASBESTOS-ST10-8/4/09	030920169-0005	North Side Sidewalk Bridge	8/4/09	1	3.080	Asbestos	PCME	EMSL	8/5/09	< 0.00080	No	No	
ASBESTOS-ST100-8/4/09	030920169-0009	Station 10 Field Duplicate	8/4/09	1	3.120	Asbestos	PCME	EMSL	8/5/09	< 0.00079	No	No	
ASBESTOS-ST11-8/4/09	030920169-0006	90 Trinity Place (roof level)	8/4/09	1	3.210	Asbestos	PCME	EMSL	8/5/09	< 0.00077	No	No	
ASBESTOS-ST12-8/4/09	030920169-0007	110 Greenwich Street (roof level)	8/4/09	1	3.100	Asbestos	PCME	EMSL	8/5/09	< 0.00080	No	No	
ASBESTOS-ST13-8/4/09	030920169-0008	Marriott Hotel, 38th Floor (roof level)	8/4/09	1	3.010	Asbestos	PCME	EMSL	8/5/09	< 0.00082	No	No	