

| TRC Field Sample No.                    | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target     | Exceeds EPA                  | Comments |
|---|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|--------------------|------------------------------|----------|
|   |                |   |                       |            |                                 |          |                   |      |                         | 0.0009                              | Air Quality Levels | Site Specific Trigger Levels |          |
|   |                |   |                       |            |                                 |          |                   |      |                         | NA                                  |                    |                              |          |
| <b>Target Air Quality Levels</b>        |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |                              |          |
| <b>EPA Site Specific Trigger Levels</b> |                |   |                       |            |                                 |          |                   |      |                         |                                     |                    |                              |          |
| ASBESTOS-ST1-8/4/08                     | 030826534-0001 | Southwest Area (sidewalk bridge level)              | 8/4/08                | 1          | 3.020                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00082                           | No                 | No                           |          |
| ASBESTOS-ST2-8/4/08                     | 030826534-0002 | Southeast Area (sidewalk bridge level)              | 8/4/08                | 1          | 3.110                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST4-8/4/08                     | 030826534-0003 | Northwest Area (street-level)                       | 8/4/08                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST5-8/4/08                     | 030826534-0004 | Firehouse #10 (roof level)                          | 8/4/08                | 1          | 2.970                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00083                           | No                 | No                           |          |
| ASBESTOS-ST10-8/4/08                    | 030826534-0005 | North Side Sidewalk Bridge                          | 8/4/08                | 1          | 3.070                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00080                           | No                 | No                           |          |
| ASBESTOS-ST100-8/4/08                   | 030826534-0012 | Station 10 Field Duplicate                          | 8/4/08                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST11-8/4/08                    | 030826534-0006 | 90 Trinity Place (roof level)                       | 8/4/08                | 1          | 3.030                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00081                           | No                 | No                           |          |
| ASBESTOS-ST12-8/4/08                    | 030826534-0007 | 110 Greenwich Street (roof level)                   | 8/4/08                | 1          | 3.060                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00081                           | No                 | No                           |          |
| ASBESTOS-ST13-8/4/08                    | 030826534-0008 | Marriott Hotel, 38th Floor (roof level)             | 8/4/08                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST14-8/4/08                    | 030826534-0009 | West Face - South end at corner (scaffolding level) | 8/4/08                | 1          | 2.920                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00085                           | No                 | No                           |          |
| ASBESTOS-ST15-8/4/08                    | 030826534-0010 | South Face - East end at corner (scaffolding level) | 8/4/08                | 1          | 3.070                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00080                           | No                 | No                           |          |
| ASBESTOS-ST16-8/4/08                    | 030826534-0011 | East Face - North end at corner (scaffolding level) | 8/4/08                | 1          | 3.010                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00082                           | No                 | No                           |          |
| ASBESTOS-ST17-8/4/08                    | 030826534-0012 | North Face - West end at corner (scaffolding level) | 8/4/08                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 8/5/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST1-8/5/08                     | 030826707-0001 | Southwest Area (sidewalk bridge level)              | 8/5/08                | 1          | 3.120                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST2-8/5/08                     | 030826707-0002 | Southeast Area (sidewalk bridge level)              | 8/5/08                | 1          | 3.110                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST4-8/5/08                     | 030826707-0003 | Northwest Area (street-level)                       | 8/5/08                | 1          | 3.140                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST5-8/5/08                     | 030826707-0004 | Firehouse #10 (roof level)                          | 8/5/08                | 1          | 3.140                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00079                           | No                 | No                           |          |
| ASBESTOS-ST10-8/5/08                    | 030826707-0005 | North Side Sidewalk Bridge                          | 8/5/08                | 1          | 2.970                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00083                           | No                 | No                           |          |
| ASBESTOS-ST11-8/5/08                    | 030826707-0006 | 90 Trinity Place (roof level)                       | 8/5/08                | 1          | 3.010                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00082                           | No                 | No                           |          |
| ASBESTOS-ST12-8/5/08                    | 030826707-0007 | 110 Greenwich Street (roof level)                   | 8/5/08                | 1          | 3.010                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00082                           | No                 | No                           |          |
| ASBESTOS-ST13-8/5/08                    | 030826707-0008 | Marriott Hotel, 38th Floor (roof level)             | 8/5/08                | 1          | 2.970                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00083                           | No                 | No                           |          |
| ASBESTOS-ST14-8/5/08                    | 030826707-0009 | West Face - South end at corner (scaffolding level) | 8/5/08                | 1          | 3.090                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00080                           | No                 | No                           |          |
| ASBESTOS-ST15-8/5/08                    | 030826707-0010 | South Face - East end at corner (scaffolding level) | 8/5/08                | 1          | 3.010                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00082                           | No                 | No                           |          |
| ASBESTOS-ST16-8/5/08                    | 030826707-0011 | East Face - North end at corner (scaffolding level) | 8/5/08                | 1          | 3.060                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00081                           | No                 | No                           |          |
| ASBESTOS-ST17-8/5/08                    | 030826707-0012 | North Face - West end at corner (scaffolding level) | 8/5/08                | 1          | 3.110                           | Asbestos | PCME              | EMSL | 8/6/08                  | < 0.00079                           | No                 | No                           |          |