

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target	Exceeds EPA	Comments
										0.0009	Air Quality Levels	Site Specific Trigger Levels	
										NA			
										Target Air Quality Levels			
										EPA Site Specific Trigger Levels			
ASBESTOS-ST1-8/24/06	030627827-0001	Southwest Area (sidewalk bridge level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST2-8/24/06	030627827-0002	Southeast Area (sidewalk bridge level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST4-8/24/06	030627827-0003	Northwest Area (street-level)	8/24/06	1	3.020	Asbestos	PCME	EMSL	8/25/06	< 0.00082	No	No	
ASBESTOS-ST5-8/24/06	030627827-0004	Firehouse #10 (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST6-8/24/06	030627833-0001	Southwest Area (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST7-8/24/06	030627833-0002	Southeast Area (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST8-8/24/06	030627833-0003	Northeast Area (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST9-8/24/06	030627833-0004	Northwest Area (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST10-8/24/06	030627827-0005	North Side Sidewalk Bridge	8/24/06	1	3.020	Asbestos	PCME	EMSL	8/25/06	< 0.00082	No	No	
ASBESTOS-ST100-8/24/06	030627827-0012	Station 10 Field Duplicate	8/24/06	1	2.790	Asbestos	PCME	EMSL	8/25/06	< 0.00088	No	No	
ASBESTOS-ST11-8/24/06	030627827-0006	90 Trinity Place (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST12-8/24/06	030627827-0007	110 Greenwich Street (roof level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST14-8/24/06	030627827-0008	West Face - South end at corner (scaffolding level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST15-8/24/06	030627827-0009	South Face - East end at corner (scaffolding level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST16-8/24/06	030627827-0010	East Face - North end at corner (scaffolding level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	
ASBESTOS-ST17-8/24/06	030627827-0011	North Face - West end at corner (scaffolding level)	8/24/06	1	2.970	Asbestos	PCME	EMSL	8/25/06	< 0.00083	No	No	

Note:

1. Asbestos sample at Station 13 (Marriott Hotel, 38th Floor [roof level]) on August 24, 2006 was not available for analysis on account of pump failure.