

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Work Shift	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Asbestos PCME Concentration (f/cm3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels										0.0009			
EPA Site Specific Trigger Levels										NA			
ASBESTOS-ST1-9/26/09	030924809-0001	Southwest Area (sidewalk bridge level)	9/26/09	1	3.030	Asbestos	PCME	EMSL	9/28/09	< 0.00081	No	No	
ASBESTOS-ST2-9/26/09	030924809-0002	Southeast Area (sidewalk bridge level)	9/26/09	1	3.000	Asbestos	PCME	EMSL	9/28/09	< 0.00082	No	No	
ASBESTOS-ST4-9/26/09	030924809-0003	Northwest Area (street-level)	9/26/09	1	2.980	Asbestos	PCME	EMSL	9/28/09	< 0.00083	No	No	
ASBESTOS-ST5-9/26/09	030924809-0004	Firehouse #10 (roof level)	9/26/09	1	3.060	Asbestos	PCME	EMSL	9/28/09	< 0.00081	No	No	
ASBESTOS-ST10-9/26/09	030924809-0005	North Side Sidewalk Bridge	9/26/09	1	2.990	Asbestos	PCME	EMSL	9/28/09	< 0.00083	No	No	
ASBESTOS-ST11-9/26/09	030924809-0006	90 Trinity Place (roof level)	9/26/09	1	2.980	Asbestos	PCME	EMSL	9/28/09	< 0.00083	No	No	
ASBESTOS-ST12-9/26/09	030924809-0007	110 Greenwich Street (roof level)	9/26/09	1	3.030	Asbestos	PCME	EMSL	9/28/09	< 0.00081	No	No	
ASBESTOS-ST13-9/26/09	030924809-0008	Marriott Hotel, 38th Floor (roof level)	9/26/09	1	3.040	Asbestos	PCME	EMSL	9/28/09	< 0.00081	No	No	
ASBESTOS-ST1-9/27/09	030924810-0001	Southwest Area (sidewalk bridge level)	9/27/09	1	2.940	Asbestos	PCME	EMSL	9/28/09	< 0.00084	No	No	
ASBESTOS-ST2-9/27/09	030924810-0002	Southeast Area (sidewalk bridge level)	9/27/09	1	3.100	Asbestos	PCME	EMSL	9/28/09	< 0.00080	No	No	
ASBESTOS-ST4-9/27/09	030924810-0003	Northwest Area (street-level)	9/27/09	1	3.000	Asbestos	PCME	EMSL	9/28/09	< 0.00082	No	No	
ASBESTOS-ST5-9/27/09	030924810-0004	Firehouse #10 (roof level)	9/27/09	1	2.920	Asbestos	PCME	EMSL	9/28/09	< 0.00085	No	No	
ASBESTOS-ST11-9/27/09	030924810-0005	90 Trinity Place (roof level)	9/27/09	1	3.010	Asbestos	PCME	EMSL	9/28/09	< 0.00082	No	No	
ASBESTOS-ST12-9/27/09	030924810-0006	110 Greenwich Street (roof level)	9/27/09	1	3.020	Asbestos	PCME	EMSL	9/28/09	< 0.00082	No	No	
ASBESTOS-ST13-9/27/09	030924810-0007	Marriott Hotel, 38th Floor (roof level)	9/27/09	1	2.970	Asbestos	PCME	EMSL	9/28/09	< 0.00083	No	No	

Note:

1. The asbestos sample from Station 10 (Northside Sidewalk Bridge) on September 27, 2009 was not available for analysis due to a pump failure.