

| TRC Field Sample No.             | Sample No.     | Sampling Location                                   | Collection Start Date | Work Shift | Sample Volume (m <sup>3</sup> ) | Analyte  | Analytical Method | Lab  | Lab Sample Receipt Date | Asbestos PCME Concentration (f/cm3) | Exceeds Target Air Quality Levels | Exceeds EPA Site Specific Trigger Levels | Comments |
|----------------------------------|----------------|---|-----------------------|------------|---------------------------------|----------|-------------------|------|-------------------------|-------------------------------------|-----------------------------------|--|----------|
| Target Air Quality Levels        |                |   |                       |            |                                 |          |                   |      |                         | 0.0009                              |                                   |  |          |
| EPA Site Specific Trigger Levels |                |   |                       |            |                                 |          |                   |      |                         | NA                                  |                                   |  |          |
| ASBESTOS-ST1-11/18/07            | 030736960-0001 | Southwest Area (sidewalk bridge level)              | 11/18/07              | 1          | 2.700                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00084                           | No                                | No                                       |          |
| ASBESTOS-ST2-11/18/07            | 030736960-0002 | Southeast Area (sidewalk bridge level)              | 11/18/07              | 1          | 3.020                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00075                           | No                                | No                                       |          |
| ASBESTOS-ST4-11/18/07            | 030736960-0003 | Northwest Area (street-level)                       | 11/18/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST5-11/18/07            | 030736960-0004 | Firehouse #10 (roof level)                          | 11/18/07              | 1          | 3.150                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00078                           | No                                | No                                       |          |
| ASBESTOS-ST10-11/18/07           | 030736960-0005 | North Side Sidewalk Bridge                          | 11/18/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST11-11/18/07           | 030736960-0006 | 90 Trinity Place (roof level)                       | 11/18/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST12-11/18/07           | 030736960-0007 | 110 Greenwich Street (roof level)                   | 11/18/07              | 1          | 3.020                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-11/18/07           | 030736960-0008 | Marriott Hotel, 38th Floor (roof level)             | 11/18/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST14-11/18/07           | 030736960-0009 | West Face - South end at corner (scaffolding level) | 11/18/07              | 1          | 2.990                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST15-11/18/07           | 030736960-0010 | South Face - East end at corner (scaffolding level) | 11/18/07              | 1          | 3.090                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST16-11/18/07           | 030736960-0011 | East Face - North end at corner (scaffolding level) | 11/18/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST17-11/18/07           | 030736960-0012 | North Face - West end at corner (scaffolding level) | 11/18/07              | 1          | 3.140                           | Asbestos | PCME              | EMSL | 11/19/07                | < 0.00079                           | No                                | No                                       |          |
| ASBESTOS-ST1-11/19/07            | 030737047-0001 | Southwest Area (sidewalk bridge level)              | 11/19/07              | 1          | 2.980                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST2-11/19/07            | 030737047-0002 | Southeast Area (sidewalk bridge level)              | 11/19/07              | 1          | 3.070                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST4-11/19/07            | 030737047-0003 | Northwest Area (street-level)                       | 11/19/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/20/07                | 0.00081                             | No                                | No                                       |          |
| ASBESTOS-ST5-11/19/07            | 030737047-0004 | Firehouse #10 (roof level)                          | 11/19/07              | 1          | 3.130                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00079                           | No                                | No                                       |          |
| ASBESTOS-ST10-11/19/07           | 030737047-0005 | North Side Sidewalk Bridge                          | 11/19/07              | 1          | 3.050                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST100-11/19/07          | 030737047-0013 | Station 10 Field Duplicate                          | 11/19/07              | 1          | 2.990                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST11-11/19/07           | 030737047-0006 | 90 Trinity Place (roof level)                       | 11/19/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST12-11/19/07           | 030737047-0007 | 110 Greenwich Street (roof level)                   | 11/19/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-11/19/07           | 030737047-0008 | Marriott Hotel, 38th Floor (roof level)             | 11/19/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST14-11/19/07           | 030737047-0009 | West Face - South end at corner (scaffolding level) | 11/19/07              | 1          | 2.990                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST15-11/19/07           | 030737047-0010 | South Face - East end at corner (scaffolding level) | 11/19/07              | 1          | 3.140                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00079                           | No                                | No                                       |          |
| ASBESTOS-ST16-11/19/07           | 030737047-0011 | East Face - North end at corner (scaffolding level) | 11/19/07              | 1          | 3.070                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST17-11/19/07           | 030737047-0012 | North Face - West end at corner (scaffolding level) | 11/19/07              | 1          | 2.940                           | Asbestos | PCME              | EMSL | 11/20/07                | < 0.00084                           | No                                | No                                       |          |
| ASBESTOS-ST1-11/20/07            | 030737129-0001 | Southwest Area (sidewalk bridge level)              | 11/20/07              | 1          | 2.930                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00084                           | No                                | No                                       |          |
| ASBESTOS-ST2-11/20/07            | 030737129-0002 | Southeast Area (sidewalk bridge level)              | 11/20/07              | 1          | 3.020                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST4-11/20/07            | 030737129-0003 | Northwest Area (street-level)                       | 11/20/07              | 1          | 3.260                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST5-11/20/07            | 030737129-0004 | Firehouse #10 (roof level)                          | 11/20/07              | 1          | 3.120                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00086                           | No                                | No                                       |          |
| ASBESTOS-ST10-11/20/07           | 030737129-0005 | North Side Sidewalk Bridge                          | 11/20/07              | 1          | 3.110                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00087                           | No                                | No                                       |          |
| ASBESTOS-ST11-11/20/07           | 030737129-0006 | 90 Trinity Place (roof level)                       | 11/20/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST12-11/20/07           | 030737129-0007 | 110 Greenwich Street (roof level)                   | 11/20/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-11/20/07           | 030737129-0008 | Marriott Hotel, 38th Floor (roof level)             | 11/20/07              | 1          | 3.060                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST14-11/20/07           | 030737129-0009 | West Face - South end at corner (scaffolding level) | 11/20/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST15-11/20/07           | 030737129-0010 | South Face - East end at corner (scaffolding level) | 11/20/07              | 1          | 3.070                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST16-11/20/07           | 030737129-0011 | East Face - North end at corner (scaffolding level) | 11/20/07              | 1          | 3.060                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST17-11/20/07           | 030737129-0012 | North Face - West end at corner (scaffolding level) | 11/20/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/21/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST1-11/21/07            | 030737218-0001 | Southwest Area (sidewalk bridge level)              | 11/21/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST2-11/21/07            | 030737218-0002 | Southeast Area (sidewalk bridge level)              | 11/21/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST4-11/21/07            | 030737218-0003 | Northwest Area (street-level)                       | 11/21/07              | 1          | 3.030                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST5-11/21/07            | 030737218-0004 | Firehouse #10 (roof level)                          | 11/21/07              | 1          | 3.020                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST10-11/21/07           | 030737218-0005 | North Side Sidewalk Bridge                          | 11/21/07              | 1          | 3.150                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00078                           | No                                | No                                       |          |
| ASBESTOS-ST11-11/21/07           | 030737218-0006 | 90 Trinity Place (roof level)                       | 11/21/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST12-11/21/07           | 030737218-0007 | 110 Greenwich Street (roof level)                   | 11/21/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-11/21/07           | 030737218-0008 | Marriott Hotel, 38th Floor (roof level)             | 11/21/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | 0.00081                             | No                                | No                                       |          |
| ASBESTOS-ST14-11/21/07           | 030737218-0009 | West Face - South end at corner (scaffolding level) | 11/21/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST15-11/21/07           | 030737218-0010 | South Face - East end at corner (scaffolding level) | 11/21/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST16-11/21/07           | 030737218-0011 | East Face - North end at corner (scaffolding level) | 11/21/07              | 1          | 2.990                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST17-11/21/07           | 030737218-0012 | North Face - West end at corner (scaffolding level) | 11/21/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST1-11/22/07            | 030737217-0001 | Southwest Area (sidewalk bridge level)              | 11/22/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00084                           | No                                | No                                       |          |
| ASBESTOS-ST4-11/22/07            | 030737217-0003 | Northwest Area (street-level)                       | 11/22/07              | 1          | 3.090                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00083                           | No                                | No                                       |          |
| ASBESTOS-ST5-11/22/07            | 030737217-0004 | Firehouse #10 (roof level)                          | 11/22/07              | 1          | 3.000                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00086                           | No                                | No                                       |          |
| ASBESTOS-ST10-11/22/07           | 030737217-0005 | North Side Sidewalk Bridge                          | 11/22/07              | 1          | 3.040                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00087                           | No                                | No                                       |          |
| ASBESTOS-ST11-11/22/07           | 030737217-0006 | 90 Trinity Place (roof level)                       | 11/22/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST12-11/22/07           | 030737217-0007 | 110 Greenwich Street (roof level)                   | 11/22/07              | 1          | 2.990                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST13-11/22/07           | 030737217-0008 | Marriott Hotel, 38th Floor (roof level)             | 11/22/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST14-11/22/07           | 030737217-0009 | West Face - South end at corner (scaffolding level) | 11/22/07              | 1          | 3.030                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00082                           | No                                | No                                       |          |
| ASBESTOS-ST15-11/22/07           | 030737217-0010 | South Face - East end at corner (scaffolding level) | 11/22/07              | 1          | 3.030                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00080                           | No                                | No                                       |          |
| ASBESTOS-ST16-11/22/07           | 030737217-0011 | East Face - North end at corner (scaffolding level) | 11/22/07              | 1          | 3.010                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |
| ASBESTOS-ST17-11/22/07           | 030737217-0012 | North Face - West end at corner (scaffolding level) | 11/22/07              | 1          | 2.970                           | Asbestos | PCME              | EMSL | 11/23/07                | < 0.00081                           | No                                | No                                       |          |

Note:

1. Due to flow rate RPD exceedance (23.8%) for asbestos at Station 1 (Southwest Area [sidewalk bridge level]) on November 18, 2007, the sample volume and subsequent sample result are estimated.
2. Asbestos sample at Station 2 (Southeast Area [sidewalk bridge level]) on November 22, 2007 was not available for analysis on account of operator error.