

TRC Field Sample No.	Station Location	Collection Start Date	Collection Time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM10 (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels							150			
EPA Site Specific Trigger Levels							150			
PM10-ST1-4/7/2006	Southwest Area (sidewalk bridge level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	27	No	No	
PM10-ST2-4/7/2006	Southeast Area (sidewalk bridge level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	37	No	No	
PM10-ST4-4/7/2006	Northwest Area (street-level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	22	No	No	
PM10-ST5-4/7/2006	Firehouse #10 (roof level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	23	No	No	
PM10-ST10-4/7/2006	North Side Sidewalk Bridge	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	27	No	No	
PM10-ST100-4/7/2006	Station 10 Field Duplicate	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	26	No	No	
PM10-ST11-4/7/2006	90 Trinity Place (roof level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	25	No	No	
PM10-ST12-4/7/2006	110 Greenwich Street (roof level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST13-4/7/2006	Marriott Hotel, 38th Floor (roof level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	18	No	No	
PM10-ST14-4/7/2006	West Face - South end at corner (scaffolding level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	22	No	No	
PM10-ST15-4/7/2006	South Face - East end at corner (scaffolding level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	21	No	No	
PM10-ST16-4/7/2006	East Face - North end at corner (scaffolding level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST17-4/7/2006	North Face - West end at corner (scaffolding level)	4/7/06	1440	Particulate	Direct Read	Met One E-BAM	22	No	No	
PM10-ST1-4/8/2006	Southwest Area (sidewalk bridge level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST2-4/8/2006	Southeast Area (sidewalk bridge level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	28	No	No	
PM10-ST4-4/8/2006	Northwest Area (street-level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST5-4/8/2006	Firehouse #10 (roof level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	25	No	No	
PM10-ST10-4/8/2006	North Side Sidewalk Bridge	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	29	No	No	
PM10-ST100-4/8/2006	Station 10 Field Duplicate	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	19	No	No	
PM10-ST11-4/8/2006	90 Trinity Place (roof level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST12-4/8/2006	110 Greenwich Street (roof level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	26	No	No	
PM10-ST13-4/8/2006	Marriott Hotel, 38th Floor (roof level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST14-4/8/2006	West Face - South end at corner (scaffolding level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	24	No	No	
PM10-ST15-4/8/2006	South Face - East end at corner (scaffolding level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST16-4/8/2006	East Face - North end at corner (scaffolding level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	10	No	No	
PM10-ST17-4/8/2006	North Face - West end at corner (scaffolding level)	4/8/06	1440	Particulate	Direct Read	Met One E-BAM	11	No	No	
PM10-ST1-4/9/2006	Southwest Area (sidewalk bridge level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	7	No	No	
PM10-ST2-4/9/2006	Southeast Area (sidewalk bridge level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST4-4/9/2006	Northwest Area (street-level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	6	No	No	
PM10-ST5-4/9/2006	Firehouse #10 (roof level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	8	No	No	
PM10-ST10-4/9/2006	North Side Sidewalk Bridge	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	8	No	No	
PM10-ST100-4/9/2006	Station 10 Field Duplicate	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	7	No	No	
PM10-ST11-4/9/2006	90 Trinity Place (roof level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	7	No	No	
PM10-ST12-4/9/2006	110 Greenwich Street (roof level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	10	No	No	
PM10-ST13-4/9/2006	Marriott Hotel, 38th Floor (roof level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	6	No	No	
PM10-ST14-4/9/2006	West Face - South end at corner (scaffolding level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	7	No	No	
PM10-ST15-4/9/2006	South Face - East end at corner (scaffolding level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	7	No	No	
PM10-ST16-4/9/2006	East Face - North end at corner (scaffolding level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	6	No	No	
PM10-ST17-4/9/2006	North Face - West end at corner (scaffolding level)	4/9/06	1440	Particulate	Direct Read	Met One E-BAM	5	No	No	