

TRC Field Sample No.	Station Location	Collection Start Date	Collection Time (minutes)	Analyte	Analytical Method	Instrument	Particulate PM10 (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
<b>Target Air Quality Levels</b>							<b>150</b>			
<b>EPA Site Specific Trigger Levels</b>							<b>150</b>			
PM10-ST1-12/28/2009	Southwest Area (sidewalk bridge level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	13	No	No	
PM10-ST2-12/28/2009	Southeast Area (sidewalk bridge level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	12	No	No	
PM10-ST4-12/28/2009	Northwest Area (street-level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	16	No	No	
PM10-ST5-12/28/2009	Firehouse #10 (roof level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST10-12/28/2009	North Side Sidewalk Bridge	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST100-12/28/2009	Station 10 Field Duplicate	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST11-12/28/2009	90 Trinity Place (roof level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	13	No	No	
PM10-ST12-12/28/2009	110 Greenwich Street (roof level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	11	No	No	
PM10-ST13-12/28/2009	Marriott Hotel, 38th Floor (roof level)	12/28/09	1440	Particulate	Direct Read	Met One E-BAM	11	No	No	
PM10-ST1-12/29/2009	Southwest Area (sidewalk bridge level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	19	No	No	
PM10-ST2-12/29/2009	Southeast Area (sidewalk bridge level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	18	No	No	
PM10-ST4-12/29/2009	Northwest Area (street-level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	22	No	No	
PM10-ST5-12/29/2009	Firehouse #10 (roof level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	17	No	No	
PM10-ST10-12/29/2009	North Side Sidewalk Bridge	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	25	No	No	
PM10-ST100-12/29/2009	Station 10 Field Duplicate	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	29	No	No	
PM10-ST11-12/29/2009	90 Trinity Place (roof level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	6	No	No	
PM10-ST12-12/29/2009	110 Greenwich Street (roof level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	20	No	No	
PM10-ST13-12/29/2009	Marriott Hotel, 38th Floor (roof level)	12/29/09	1440	Particulate	Direct Read	Met One E-BAM	19	No	No	