

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target	Exceeds EPA	Comments
									10	Air Quality Levels	Site Specific Trigger Levels	
									10			
SILICA-ST1-4/30/07	040708898-0001	Southwest Area (sidewalk bridge level)	4/30/07	3.71	Silica	NIOSH 7500 XRD	EMSL	5/1/07	2	No	No	
SILICA-ST2-4/30/07	040708898-0002	Southeast Area (sidewalk bridge level)	4/30/07	3.71	Silica	NIOSH 7500 XRD	EMSL	5/1/07	2	No	No	
SILICA-ST4-4/30/07	040708898-0003	Northwest Area (street-level)	4/30/07	3.57	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST5-4/30/07	040708898-0004	Firehouse #10 (roof level)	4/30/07	3.6	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST10-4/30/07	040708898-0005	North Side Sidewalk Bridge	4/30/07	3.59	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST11-4/30/07	040708898-0006	90 Trinity Place (roof level)	4/30/07	3.67	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST12-4/30/07	040708898-0007	110 Greenwich Street (roof level)	4/30/07	3.67	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST13-4/30/07	040708898-0008	Marriott Hotel, 38th Floor (roof level)	4/30/07	3.59	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST14(30th) -4/30/07	040708898-0009	West Face - South end at corner (scaffolding level: 30th floor)	4/30/07	3.7	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST15(30th) -4/30/07	040708898-0010	South Face - East end at corner (scaffolding level: 30th floor)	4/30/07	3.61	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST16(30th) -4/30/07	040708898-0011	East Face - North end at corner (scaffolding level: 30th floor)	4/30/07	3.68	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST17(30th) -4/30/07	040708898-0012	North Face - West end at corner (scaffolding level: 30th floor)	4/30/07	3.69	Silica	NIOSH 7500 XRD	EMSL	5/1/07	< 1	No	No	
SILICA-ST1-5/1/07	040708987-0001	Southwest Area (sidewalk bridge level)	5/1/07	3.62	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST2-5/1/07	040708987-0002	Southeast Area (sidewalk bridge level)	5/1/07	3.57	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST4-5/1/07	040708987-0003	Northwest Area (street-level)	5/1/07	3.74	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST5-5/1/07	040708987-0004	Firehouse #10 (roof level)	5/1/07	3.53	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST10-5/1/07	040708987-0005	North Side Sidewalk Bridge	5/1/07	3.64	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST11-5/1/07	040708987-0006	90 Trinity Place (roof level)	5/1/07	3.29	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 2	No	No	
SILICA-ST12-5/1/07	040708987-0007	110 Greenwich Street (roof level)	5/1/07	3.66	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST13-5/1/07	040708987-0008	Marriott Hotel, 38th Floor (roof level)	5/1/07	3.58	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST14(30th) -5/1/07	040708987-0009	West Face - South end at corner (scaffolding level: 30th floor)	5/1/07	3.73	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST15(30th) -5/1/07	040708987-0010	South Face - East end at corner (scaffolding level: 30th floor)	5/1/07	3.69	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST16(30th) -5/1/07	040708987-0011	East Face - North end at corner (scaffolding level: 30th floor)	5/1/07	3.65	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	
SILICA-ST17(30th) -5/1/07	040708987-0012	North Face - West end at corner (scaffolding level: 30th floor)	5/1/07	3.69	Silica	NIOSH 7500 XRD	EMSL	5/2/07	< 1	No	No	