

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
									10			
									10			
SILICA-ST1-7/14/06	040614522-0001	Southwest Area (sidewalk bridge level)	7/14/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST2-7/14/06	040614522-0002	Southeast Area (sidewalk bridge level)	7/14/06	3.55	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST4-7/14/06	040614522-0003	Northwest Area (street-level)	7/14/06	3.55	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST5-7/14/06	040614522-0004	Firehouse #10 (roof level)	7/14/06	3.4	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST6-7/14/06	040614525-0001	Southwest Area (roof level)	7/14/06	3.66	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST7-7/14/06	040614525-0002	Southeast Area (roof level)	7/14/06	3.69	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST8-7/14/06	040614525-0003	Northeast Area (roof level)	7/14/06	3.69	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST9-7/14/06	040614525-0004	Northwest Area (roof level)	7/14/06	3.67	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST10-7/14/06	040614522-0005	North Side Sidewalk Bridge	7/14/06	3.46	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST11-7/14/06	040614522-0006	90 Trinity Place (roof level)	7/14/06	3.53	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST12-7/14/06	040614522-0007	110 Greenwich Street (roof level)	7/14/06	3.71	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST13-7/14/06	040614522-0008	Marriott Hotel, 38th Floor (roof level)	7/14/06	3.54	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST14-7/14/06	040614522-0009	West Face - South end at corner (scaffolding level)	7/14/06	3.46	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST15-7/14/06	040614522-0010	South Face - East end at corner (scaffolding level)	7/14/06	3.5	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST16-7/14/06	040614522-0011	East Face - North end at corner (scaffolding level)	7/14/06	3.47	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST17-7/14/06	040614522-0012	North Face - West end at corner (scaffolding level)	7/14/06	3.47	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST1-7/15/06	040614526-0001	Southwest Area (sidewalk bridge level)	7/15/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST2-7/15/06	040614526-0002	Southeast Area (sidewalk bridge level)	7/15/06	3.59	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST4-7/15/06	040614526-0003	Northwest Area (street-level)	7/15/06	3.54	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST5-7/15/06	040614526-0004	Firehouse #10 (roof level)	7/15/06	3.69	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST6-7/15/06	040614528-0001	Southwest Area (roof level)	7/15/06	3.54	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST7-7/15/06	040614528-0002	Southeast Area (roof level)	7/15/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST8-7/15/06	040614528-0003	Northeast Area (roof level)	7/15/06	3.54	Silica	NIOSH 7500 XRD	EMSL	7/17/06	1	No	No	
SILICA-ST9-7/15/06	040614528-0004	Northwest Area (roof level)	7/15/06	3.54	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST10-7/15/06	040614526-0005	North Side Sidewalk Bridge	7/15/06	3.53	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST11-7/15/06	040614526-0006	90 Trinity Place (roof level)	7/15/06	3.61	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST12-7/15/06	040614526-0007	110 Greenwich Street (roof level)	7/15/06	3.5	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST13-7/15/06	040614526-0008	Marriott Hotel, 38th Floor (roof level)	7/15/06	3.55	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST14-7/15/06	040614526-0009	West Face - South end at corner (scaffolding level)	7/15/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST15-7/15/06	040614526-0010	South Face - East end at corner (scaffolding level)	7/15/06	3.56	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST16-7/15/06	040614526-0011	East Face - North end at corner (scaffolding level)	7/15/06	3.56	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST17-7/15/06	040614526-0012	North Face - West end at corner (scaffolding level)	7/15/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST1-7/16/06	040614530-0001	Southwest Area (sidewalk bridge level)	7/16/06	3.7	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST2-7/16/06	040614530-0002	Southeast Area (sidewalk bridge level)	7/16/06	3.71	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST4-7/16/06	040614530-0003	Northwest Area (street-level)	7/16/06	3.7	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST5-7/16/06	040614530-0004	Firehouse #10 (roof level)	7/16/06	3.6	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST6-7/16/06	040614534-0001	Southwest Area (roof level)	7/16/06	3.51	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST7-7/16/06	040614534-0002	Southeast Area (roof level)	7/16/06	3.52	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST8-7/16/06	040614534-0003	Northeast Area (roof level)	7/16/06	3.53	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST9-7/16/06	040614534-0004	Northwest Area (roof level)	7/16/06	3.52	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST10-7/16/06	040614530-0005	North Side Sidewalk Bridge	7/16/06	3.64	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST11-7/16/06	040614530-0006	90 Trinity Place (roof level)	7/16/06	3.55	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST12-7/16/06	040614530-0007	110 Greenwich Street (roof level)	7/16/06	3.5	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST13-7/16/06	040614530-0008	Marriott Hotel, 38th Floor (roof level)	7/16/06	3.68	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST14-7/16/06	040614530-0009	West Face - South end at corner (scaffolding level)	7/16/06	3.77	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST15-7/16/06	040614530-0010	South Face - East end at corner (scaffolding level)	7/16/06	3.76	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST16-7/16/06	040614530-0011	East Face - North end at corner (scaffolding level)	7/16/06	3.77	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST17-7/16/06	040614530-0012	North Face - West end at corner (scaffolding level)	7/16/06	3.75	Silica	NIOSH 7500 XRD	EMSL	7/17/06	< 1	No	No	
SILICA-ST1-7/17/06	040614652-0001	Southwest Area (sidewalk bridge level)	7/17/06	3.74	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST2-7/17/06	040614652-0002	Southeast Area (sidewalk bridge level)	7/17/06	3.72	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST4-7/17/06	040614652-0003	Northwest Area (street-level)	7/17/06	3.66	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST5-7/17/06	040614652-0004	Firehouse #10 (roof level)	7/17/06	3.6	Silica	NIOSH 7500 XRD	EMSL	7/18/06	2	No	No	
SILICA-ST6-7/17/06	040614654-0001	Southwest Area (roof level)	7/17/06	3.47	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST7-7/17/06	040614654-0002	Southeast Area (roof level)	7/17/06	3.48	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST8-7/17/06	040614654-0003	Northeast Area (roof level)	7/17/06	3.48	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST9-7/17/06	040614654-0004	Northwest Area (roof level)	7/17/06	3.48	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST10-7/17/06	040614652-0005	North Side Sidewalk Bridge	7/17/06	3.59	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST11-7/17/06	040614652-0006	90 Trinity Place (roof level)	7/17/06	3.62	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST12-7/17/06	040614652-0007	110 Greenwich Street (roof level)	7/17/06	3.64	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST13-7/17/06	040614652-0008	Marriott Hotel, 38th Floor (roof level)	7/17/06	3.68	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST14-7/17/06	040614652-0009	West Face - South end at corner (scaffolding level)	7/17/06	3.58	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST15-7/17/06	040614652-0010	South Face - East end at corner (scaffolding level)	7/17/06	3.56	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST16-7/17/06	040614652-0011	East Face - North end at corner (scaffolding level)	7/17/06	3.57	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	
SILICA-ST17-7/17/06	040614652-0012	North Face - West end at corner (scaffolding level)	7/17/06	3.56	Silica	NIOSH 7500 XRD	EMSL	7/18/06	< 1	No	No	