

TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m ³)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target	Exceeds EPA	Comments
									10	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	
									10			
Target Air Quality Levels												
EPA Site Specific Trigger Levels												
SILICA-ST1-9/4/09	040922414-0001	Southwest Area (sidewalk bridge level)	9/4/09	3.51	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST2-9/4/09	040922414-0002	Southeast Area (sidewalk bridge level)	9/4/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST4-9/4/09	040922414-0003	Northwest Area (street-level)	9/4/09	3.63	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST5-9/4/09	040922414-0004	Firehouse #10 (roof level)	9/4/09	3.63	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST10-9/4/09	040922414-0005	North Side Sidewalk Bridge	9/4/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST11-9/4/09	040922414-0006	90 Trinity Place (roof level)	9/4/09	3.56	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST12-9/4/09	040922414-0007	110 Greenwich Street (roof level)	9/4/09	3.53	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST13-9/4/09	040922414-0008	Marriott Hotel, 38th Floor (roof level)	9/4/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/5/09	< 1	No	No	
SILICA-ST1-9/5/09	040922474-0001	Southwest Area (sidewalk bridge level)	9/5/09	3.62	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST2-9/5/09	040922474-0002	Southeast Area (sidewalk bridge level)	9/5/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST4-9/5/09	040922474-0003	Northwest Area (street-level)	9/5/09	3.62	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST5-9/5/09	040922474-0004	Firehouse #10 (roof level)	9/5/09	3.67	Silica	NIOSH 7500 XRD	EMSL	9/8/09	3	No	No	
SILICA-ST10-9/5/09	040922474-0005	North Side Sidewalk Bridge	9/5/09	3.5	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST11-9/5/09	040922474-0006	90 Trinity Place (roof level)	9/5/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST12-9/5/09	040922474-0007	110 Greenwich Street (roof level)	9/5/09	3.56	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST13-9/5/09	040922474-0008	Marriott Hotel, 38th Floor (roof level)	9/5/09	3.59	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST1-9/6/09	040922477-0001	Southwest Area (sidewalk bridge level)	9/6/09	3.6	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST2-9/6/09	040922477-0002	Southeast Area (sidewalk bridge level)	9/6/09	3.62	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST4-9/6/09	040922477-0003	Northwest Area (street-level)	9/6/09	3.71	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST5-9/6/09	040922477-0004	Firehouse #10 (roof level)	9/6/09	3.55	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST10-9/6/09	040922477-0005	North Side Sidewalk Bridge	9/6/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST11-9/6/09	040922477-0006	90 Trinity Place (roof level)	9/6/09	3.61	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST12-9/6/09	040922477-0007	110 Greenwich Street (roof level)	9/6/09	3.61	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST13-9/6/09	040922477-0008	Marriott Hotel, 38th Floor (roof level)	9/6/09	3.6	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST1-9/7/09	040922475-0001	Southwest Area (sidewalk bridge level)	9/7/09	3.69	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST2-9/7/09	040922475-0002	Southeast Area (sidewalk bridge level)	9/7/09	3.66	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST4-9/7/09	040922475-0003	Northwest Area (street-level)	9/7/09	3.57	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST5-9/7/09	040922475-0004	Firehouse #10 (roof level)	9/7/09	3.66	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST10-9/7/09	040922475-0005	North Side Sidewalk Bridge	9/7/09	3.62	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST11-9/7/09	040922475-0006	90 Trinity Place (roof level)	9/7/09	3.73	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST12-9/7/09	040922475-0007	110 Greenwich Street (roof level)	9/7/09	3.65	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	
SILICA-ST13-9/7/09	040922475-0008	Marriott Hotel, 38th Floor (roof level)	9/7/09	3.55	Silica	NIOSH 7500 XRD	EMSL	9/8/09	< 1	No	No	