

| TRC Field Sample No.          | Sample No.     | Sampling Location   | Collection Start Date | Sample Volume (m <sup>3</sup> ) | Analyte | Analytical Method | Lab  | Lab Sample Receipt Date | Respirable Silica Concentration (ug/m3) | Exceeds Target     | Exceeds EPA                  | Comments |
|-------------------------------|----------------|---|-----------------------|---------------------------------|---------|-------------------|------|-------------------------|---|--------------------|------------------------------|----------|
|                               |                |   |                       |                                 |         |                   |      |                         | <b>10</b>                               | Air Quality Levels | Site Specific Trigger Levels |          |
|                               |                |   |                       |                                 |         |                   |      |                         | <b>10</b>                               |                    |                              |          |
| SILICA-ST1-9/23/08            | 040825043-0001 | Southwest Area (sidewalk bridge level)                          | 9/23/08               | 3.67                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST2-9/23/08            | 040825043-0002 | Southeast Area (sidewalk bridge level)                          | 9/23/08               | 3.65                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | 2                                       | No                 | No                           |          |
| SILICA-ST4-9/23/08            | 040825043-0003 | Northwest Area (street-level)                                   | 9/23/08               | 3.57                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST5-9/23/08            | 040825043-0004 | Firehouse #10 (roof level)                                      | 9/23/08               | 3.54                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST10-9/23/08           | 040825043-0005 | North Side Sidewalk Bridge                                      | 9/23/08               | 3.58                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST100-9/23/08          | 040825043-0013 | Station 10 Field Duplicate                                      | 9/23/08               | 3.47                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 6                                     | No                 | No                           |          |
| SILICA-ST11-9/23/08           | 040825043-0006 | 90 Trinity Place (roof level)                                   | 9/23/08               | 3.62                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST12-9/23/08           | 040825043-0007 | 110 Greenwich Street (roof level)                               | 9/23/08               | 3.61                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | 1                                       | No                 | No                           |          |
| SILICA-ST13-9/23/08           | 040825043-0008 | Marriott Hotel, 38th Floor (roof level)                         | 9/23/08               | 3.59                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST14 15th Flr -9/23/08 | 040825043-0009 | West Face - South end at corner (scaffolding level: 15th floor) | 9/23/08               | 3.73                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST15 15th Flr -9/23/08 | 040825043-0010 | South Face - East end at corner (scaffolding level: 15th floor) | 9/23/08               | 3.58                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST16 15th Flr -9/23/08 | 040825043-0011 | East Face - North end at corner (scaffolding level: 15th floor) | 9/23/08               | 3.59                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 6                                     | No                 | No                           |          |
| SILICA-ST17 15th Flr -9/23/08 | 040825043-0012 | North Face - West end at corner (scaffolding level: 15th floor) | 9/23/08               | 3.58                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/24/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST1-9/24/08            | 040825147-0001 | Southwest Area (sidewalk bridge level)                          | 9/24/08               | 3.63                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST2-9/24/08            | 040825147-0002 | Southeast Area (sidewalk bridge level)                          | 9/24/08               | 3.59                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST4-9/24/08            | 040825147-0003 | Northwest Area (street-level)                                   | 9/24/08               | 3.64                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | 7                                       | No                 | No                           |          |
| SILICA-ST5-9/24/08            | 040825147-0004 | Firehouse #10 (roof level)                                      | 9/24/08               | 3.59                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | 1                                       | No                 | No                           |          |
| SILICA-ST10-9/24/08           | 040825147-0005 | North Side Sidewalk Bridge                                      | 9/24/08               | 3.67                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST11-9/24/08           | 040825147-0006 | 90 Trinity Place (roof level)                                   | 9/24/08               | 3.61                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | 2                                       | No                 | No                           |          |
| SILICA-ST12-9/24/08           | 040825147-0007 | 110 Greenwich Street (roof level)                               | 9/24/08               | 3.61                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST13-9/24/08           | 040825147-0008 | Marriott Hotel, 38th Floor (roof level)                         | 9/24/08               | 3.62                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | 2                                       | No                 | No                           |          |
| SILICA-ST14 15th Flr -9/24/08 | 040825147-0009 | West Face - South end at corner (scaffolding level: 15th floor) | 9/24/08               | 3.67                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | 1                                       | No                 | No                           |          |
| SILICA-ST15 15th Flr -9/24/08 | 040825147-0010 | South Face - East end at corner (scaffolding level: 15th floor) | 9/24/08               | 3.69                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST16 15th Flr -9/24/08 | 040825147-0011 | East Face - North end at corner (scaffolding level: 15th floor) | 9/24/08               | 3.57                            | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |
| SILICA-ST17 15th Flr -9/24/08 | 040825147-0012 | North Face - West end at corner (scaffolding level: 15th floor) | 9/24/08               | 3.6                             | Silica  | NIOSH 7500 XRD    | EMSL | 9/25/08                 | < 1                                     | No                 | No                           |          |