TRC Field Sample No.	Sample No.	Sampling Location	Collection Start Date	Sample Volume (m^3)	Analyte	Analytical Method	Lab	Lab Sample Receipt Date	Respirable Silica Concentration (ug/m3)	Exceeds Target Air Quality Levels	Exceeds EPA Site Specific Trigger Levels	Comments
Target Air Quality Levels									**10**			
EPA Site Specific Trigger Levels									**10**			
SILICA-ST1-11/21/07	040729203-0001	Southwest Area (sidewalk bridge level)	11/21/07	3.5	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST2-11/21/07	040729203-0002	Southeast Area (sidewalk bridge level)	11/21/07	3.45	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST4-11/21/07	040729203-0003	Northwest Area (street-level)	11/21/07	3.47	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST5-11/21/07	040729203-0004	Firehouse #10 (roof level)	11/21/07	3.49	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST10-11/21/07	040729203-0005	North Side Sidewalk Bridge	11/21/07	3.54	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST11-11/21/07	040729203-0006	90 Trinity Place (roof level)	11/21/07	3.56	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST12-11/21/07	040729203-0007	110 Greenwich Street (roof level)	11/21/07	3.42	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST13-11/21/07	040729203-0008	Marriott Hotel, 38th Floor (roof level)	11/21/07	3.52	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST14(15th) -11/21/07	040729203-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/21/07	3.4	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST15(15th) -11/21/07	040729203-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/21/07	3.37	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST16(15th) -11/21/07	040729203-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/21/07	3.38	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST17(15th) -11/21/07	040729203-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/21/07	3.35	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST1-11/22/07	040729204-0001	Southwest Area (sidewalk bridge level)	11/22/07	3.84	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST2-11/22/07	040729204-0002	Southeast Area (sidewalk bridge level)	11/22/07	3.61	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST4-11/22/07	040729204-0003	Northwest Area (street-level)	11/22/07	3.68	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST5-11/22/07	040729204-0004	Firehouse #10 (roof level)	11/22/07	3.56	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST10-11/22/07	040729204-0005	North Side Sidewalk Bridge	11/22/07	3.64	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST11-11/22/07	040729204-0006	90 Trinity Place (roof level)	11/22/07	3.56	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST12-11/22/07	040729204-0007	110 Greenwich Street (roof level)	11/22/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST13-11/22/07	040729204-0008	Marriott Hotel, 38th Floor (roof level)	11/22/07	3.55	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST14(15th) -11/22/07	040729204-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/22/07	3.6	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST15(15th) -11/22/07	040729204-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/22/07	3.55	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST16(15th) -11/22/07	040729204-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/22/07	3.54	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST17(15th) -11/22/07	040729204-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/22/07	3.54	Silica	NIOSH 7500 XRD	EMSL	11/24/07	< 1	No	No	
SILICA-ST1-11/23/07	040729281-0001	Southwest Area (sidewalk bridge level)	11/23/07	3.55	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST2-11/23/07	040729281-0002	Southeast Area (sidewalk bridge level)	11/23/07	3.68	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST4-11/23/07	040729281-0003	Northwest Area (street-level)	11/23/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST5-11/23/07	040729281-0004	Firehouse #10 (roof level)	11/23/07	3.62	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST10-11/23/07	040729281-0005	North Side Sidewalk Bridge	11/23/07	3.66	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST11-11/23/07	040729281-0006	90 Trinity Place (roof level)	11/23/07	3.66	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST12-11/23/07	040729281-0007	110 Greenwich Street (roof level)	11/23/07	3.5	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST13-11/23/07	040729281-0008	Marriott Hotel, 38th Floor (roof level)	11/23/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST14(15th) -11/23/07	040729281-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/23/07	3.64	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST15(15th) -11/23/07	040729281-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/23/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST16(15th) -11/23/07	040729281-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/23/07	3.59	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST17(15th) -11/23/07	040729281-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/23/07	3.55	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST1-11/24/07	040729280-0001	Southwest Area (sidewalk bridge level)	11/24/07	3.6	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST2-11/24/07	040729280-0002	Southeast Area (sidewalk bridge level)	11/24/07	3.5	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST4-11/24/07	040729280-0003	Northwest Area (street-level)	11/24/07	3.73	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST5-11/24/07	040729280-0004	Firehouse #10 (roof level)	11/24/07	3.52	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST10-11/24/07	040729280-0005	North Side Sidewalk Bridge	11/24/07	3.54	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST11-11/24/07	040729280-0006	90 Trinity Place (roof level)	11/24/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST12-11/24/07	040729280-0007	110 Greenwich Street (roof level)	11/24/07	3.59	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST13-11/24/07	040729280-0008	Marriott Hotel, 38th Floor (roof level)	11/24/07	3.56	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST14(15th) -11/24/07	040729280-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/24/07	3.54	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST15(15th) -11/24/07	040729280-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/24/07	3.48	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST16(15th) -11/24/07	040729280-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/24/07	3.44	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST17(15th) -11/24/07	040729280-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/24/07	3.55	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST1-11/25/07	040729282-0001	Southwest Area (sidewalk bridge level)	11/25/07	3.63	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST2-11/25/07	040729282-0002	Southeast Area (sidewalk bridge level)	11/25/07	3.65	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST4-11/25/07	040729282-0003	Northwest Area (street-level)	11/25/07	3.62	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST5-11/25/07	040729282-0004	Firehouse #10 (roof level)	11/25/07	3.71	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST10-11/25/07	040729282-0005	North Side Sidewalk Bridge	11/25/07	3.52	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST11-11/25/07	040729282-0006	90 Trinity Place (roof level)	11/25/07	3.57	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST12-11/25/07	040729282-0007	110 Greenwich Street (roof level)	11/25/07	3.69	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST13-11/25/07	040729282-0008	Marriott Hotel, 38th Floor (roof level)	11/25/07	3.7	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST14(15th) -11/25/07	040729282-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/25/07	3.96	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST15(15th) -11/25/07	040729282-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/25/07	4.05	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST16(15th) -11/25/07	040729282-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/25/07	3.95	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST17(15th) -11/25/07	040729282-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/25/07	3.88	Silica	NIOSH 7500 XRD	EMSL	11/26/07	< 1	No	No	
SILICA-ST1-11/26/07	040729395-0001	Southwest Area (sidewalk bridge level)	11/26/07	3.58	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST2-11/26/07	040729395-0002	Southeast Area (sidewalk bridge level)	11/26/07	3.79	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST4-11/26/07	040729395-0003	Northwest Area (street-level)	11/26/07	3.62	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST5-11/26/07	040729395-0004	Firehouse #10 (roof level)	11/26/07	3.7	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST10-11/26/07	040729395-0005	North Side Sidewalk Bridge	11/26/07	3.62	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST11-11/26/07	040729395-0006	90 Trinity Place (roof level)	11/26/07	3.53	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST12-11/26/07	040729395-0007	110 Greenwich Street (roof level)	11/26/07	3.6	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST13-11/26/07	040729395-0008	Marriott Hotel, 38th Floor (roof level)	11/26/07	3.52	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST14(15th) -11/26/07	040729395-0009	West Face - South end at corner (scaffolding level: 15th floor)	11/26/07	3.67	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST15(15th) -11/26/07	040729395-0010	South Face - East end at corner (scaffolding level: 15th floor)	11/26/07	3.74	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST16(15th) -11/26/07	040729395-0011	East Face - North end at corner (scaffolding level: 15th floor)	11/26/07	3.74	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	
SILICA-ST17(15th) -11/26/07	040729395-0012	North Face - West end at corner (scaffolding level: 15th floor)	11/26/07	3.65	Silica	NIOSH 7500 XRD	EMSL	11/27/07	< 1	No	No	